



TRENCH

NOTES

1. PROPERTY OWNER TO COMPLY WITH ALL MPL REQUIREMENTS, STANDARDS AND SPECIFICATIONS.
2. THE PROPERTY OWNER IS RESPONSIBLE FOR REQUESTING UTILITY LOCATES THROUGH THE OREGON UTILITY NOTIFICATION CENTER, 1-800-332-2344, FOR THE ENTIRE PROJECT PRIOR TO THE BEGINNING OF CONSTRUCTION. THE CONTRACTOR SHALL VERIFY THE DEPTH AND LOCATION OF ALL EXISTING UTILITIES WITHIN THE PROJECT LIMITS PRIOR TO BEGINNING CONSTRUCTION.
3. PROPERTY OWNER TO SUPPLY AND INSTALL ELECTRICALLY RATED CONDUIT (2" FOR PRIMARY & 3" FOR SECONDARY SERVICE), CONDUIT ELBOWS, PULL LINES AND IDENTIFICATION TAPE .
4. PROPERTY OWNER TO INSTALL IDENTIFICATION TAPE ABOVE PRIMARY ELECTRICAL CONDUITS. IDENTIFICATION TAPE SHALL BE 6-INCH WIDE, RED TAPE AND SHALL READ 'CAUTION BURIED ELECTRICAL INSTALLATION BELOW', OR SHALL IDENTIFY THE APPROPRIATE UTILITY. THE TAPE SHALL BE PLACED 12 INCHES ABOVE THE CONDUIT.
5. ALL PRIMARY ELECTRICAL CONDUIT TO BE INSTALLED WITH MINIMUM OF 42" AND MAXIMUM OF 60" COVER.
6. ALL SECONDARY & SERVICE CONDUIT TO METER BASES, ARE TO BE INSTALLED WITH MINIMUM OF 24" COVER FROM FINISH GRADE, UNLESS OTHERWISE NOTED
7. MPL SHALL INSPECT AND APPROVE ALL TRENCHES PRIOR TO BACKFILL (503.838.3526).
8. PLACEMENT OF ALL BACKFILL SHALL BE DONE IN 6-INCH LIFTS WITH EACH LIFT COMPACTED.
9. A WIRE BRUSH MANDREL OF PROPER SIZE SHALL BE PULLED THROUGH ALL CONDUIT RUNS TO ENSURE CONDUITS ARE SMOOTH AND FREE OF DEBRIS AFTER INSTALLATION.



MONMOUTH POWER & LIGHT
401 HOGAN ROAD
MONMOUTH, OREGON 97361
P:503.838.3526 // F:503.838.0201
mpl@ci.monmouth.or.us

TRENCH DETAILS TYPICAL

SIZE	SCALE	ENG	DRN	DATE	PROJECT No.	DRAWING No.	SHEETS	REV
A	NTS	MPL	LM	02/17/17			1 OF 1	1